Energy Tips








Steam

Motors

Compressed Air



Recommended Steam Trap Testing Intervals

- High Pressure (150 psig and above): Weekly to Monthly
- Medium Pressure (30 to 150 psig): Monthly to Quarterly
- Low Pressure (Below 30 psig): Annually

Adapted from an EnergyTIPS fact sheet that was originally published by the Industrial Energy Extension Service of Georgia Tech. For additional information on steam system efficiency measures, contact the Information Clearinghouse at (800) 862-2086.



Inspect and Repair Steam Traps

In steam systems that have not been maintained for 3 to 5 years, between 15% to 30% of the installed steam traps may have failed—thus allowing live steam to escape into the condensate return system. In systems with a regularly scheduled maintenance program, leaking traps should account for less than 5% of the trap population. If your steam distribution system includes more than 500 traps, a steam trap survey will probably reveal significant steam losses.

Example

In a plant where the value of steam is \$4.50 per thousand pounds (\$/1,000 lbs), an inspection program indicates that a trap on a 150 psig steam line is stuck open. The trap orifice is 1/8 inch in diameter. The table shows the estimated steam loss as 75.8 lbs/hr. By repairing the failed trap, annual savings are:

Savings = 75.8 lbs/hr x 8,760 hrs/yr x \$4.50/1,000 lbs = \$2,988/yr

Leaking Steam Trap Discharge Rate				
	Steam Loss (lbs/hr)			
Trap Orifice Diameter (inches)	Steam Pressure (psig)			
	15	100	150	300
1/32	0.85	3.3	4.8	-
1/16	3.4	13.2	18.9	36.2
1/8	13.7	52.8	75.8	145
3/16	30.7	119	170	326
1/4	54.7	211	303	579
3/8	123	475	682	1,303

From the Boiler Efficiency Institute. Steam is discharging to atmospheric pressure.

Steam Trap Testing Facts

Steam traps are tested to determine if they are functioning properly and not cold plugging or failing in an open position and allowing live steam to escape into the condensate return system. There are four basic ways to test steam traps: temperature, sound, visual, and electronic.

Suggested Actions

Steam traps are tested primarily to determine whether they are functioning properly and not allowing live steam to blow through. Establish a program for the regular systematic inspection, testing, and repair of steam traps. Include a reporting mechanism to ensure thoroughness and to provide a means of documenting energy and dollar savings.

About DOE's Office of Industrial Technologies

The Office of Industrial Technologies (OIT), through partnerships with industry, government, and non-governmental organizations, develops and delivers advanced energy efficiency, renewable energy, and pollution prevention technologies for industrial applications. OIT is part of the U.S. Department of Energy's Office of Energy Efficiency and Renewable Energy.

OIT encourages industry-wide efforts to boost resource productivity through a strategy called Industries of the Future (IOF). IOF focuses on the following nine energy and resource intensive industries:

Agriculture Chemicals Glass Mining Steel
Aluminum Forest Products Metal Casting Petroleum

To help industries begin to save energy, reduce costs, and cut pollution right away, IOF technical assistance programs offer a comprehensive portfolio of emerging technology, practices, tools, information, and resources in a variety of application areas, for example, motor systems, steam systems, compressed air systems, and combined heat and power systems. Likewise, IOF has Industrial Assessment Centers (IAC) throughout the U.S. that offer energy, waste, and productivity assessments to small and medium-sized manufacturers. Users can take advantage of the abundant resources, such as software, fact sheets, training materials, etc. available from the IOF technical assistance programs.

Motor Systems — helps industry increase productivity and reliability through energy-efficient electric motor-driven systems. **Documents** -Software -☐ Buying an Energy-Efficient Electric Motor ☐ MotorMaster+ 3.0 and training CD ☐ Optimizing Your Motor-Driven System □ ASDMaster ☐ Frequently Asked Questions on: The Impacts of the ☐ Pumping System Assessment Tool Energy Policy Act of 1992 on Industrial End Users of Training -Electric Motor-Driven Systems ☐ MotorMaster+ 3.0 Software ☐ Energy Management for Motor Driven Systems ☐ Adjustable Speed Drive Application ☐ Improving Pumping System Performance: A Sourcebook ☐ Pumping System Optimization for Industry ☐ Pumping System Assessment Tool Access the Web site at www.motor.doe.gov. Steam Systems — helps industry enhance productivity, increase profits, and reduce emissions through better steam system management. Documents -Case Studies -☐ Energy Efficiency Handbook ☐ Georgia Pacific Achieves 6-Month Payback ☐ Plant Services Article - The Steam Challenge ☐ Bethlehem Steel Showcase Demonstration ☐ Energy Manager Article - Steaming Ahead Software -☐ Oak Ridge National Laboratory's Insulation Guidelines ☐ 3EPlus Software for Determining Optimal Insulation Thickness ☐ 1998 IETC Steam Session Papers Access the Web site at www.oit.doe.gov/steam. **Compressed Air Systems** — dedicated to improving the efficiency and performance of industrial compressed air systems. Documents -Training -☐ Improving Compressed Air System Performance: ☐ Fundamentals of Compressed Air Systems A Sourcebook for Industry (For schedule and location, call (800) 862-2086) Access the Web site at www.knowpressure.org. Industrial Assessment Centers — enable small and medium-sized manufacturers to have comprehensive industrial assessments performed at no cost to the manufacturer. Documents -Access the Web site at www.oit.doe.gov/iac. □ IAC Database For more information, simply check the box next to the product, fill out the form below and fax back to (360) 586-8303: _____Title: _____ Name: ___ Organization: _____

For more information on Motor, Steam, Compressed Air Systems, and IACs, call the Information Clearinghouse at (800) 862-2086. For overall OIT and IOF information, contact the OIT Resource Room at (202) 586-2090 or access the Web site at www.oit.doe.gov.

Fax: E-mail:

Comments:

State: Zip: